

Date: March 7, 2016

Subject: Addendum No. 1 to Questions and Responses for Alameda Municipal Power Request for Proposal (RFP) for VIDEO SECURITY AND SURVEILLANCE SYSTEM WITH TECHNICAL SUPPORT, SPECIFICATION NO. PS 01-16-03

Proposal Due Date: 3:00 p.m. Pacific Time, Thursday, March 10, 2016

Please note the following changes, corrections, and clarifications that are hereby incorporated to the requirements of the RFP:

Question #1 Reference page 1 – paragraph 7, can the due date be extended 1 week?  
Response #1 No

Question #2 Reference page 37 paragraph 4.7.3, is AMP providing this equipment?  
Response #2 Yes, AMP will be providing the following: boxes, Ethernet switches and power supplies for switches.

Question #3 Reference page 35 paragraph 2.18, is AMP going to make any needed cabling modifications to get the cable to the new NVR? Rather than a hybrid NVR are Analog to Digital edge converters ok?  
Response #3 AMP will make any and all necessary cable modifications. Analog to Digital edge converters is acceptable.

Question #4 Reference page 11 paragraph 3-a, since we are not installing the equipment can it be billed once delivered on site?  
Response #4 Yes

Question #5 3.1.2.9. Ability to tie in existing card readers into the system. Can you please provide detailed requirements on the level of integration expected? i.e. would digital inputs suffice?  
Response #5 AMP currently uses AMAG card reader security system and may integrate the AMAG system into the new video security system in the future.

- Question #6 5.3.2 Ability to add infrared photoelectric beams.  
Can you please provide detailed requirements on the level of integration expected? i.e. would digital inputs suffice?
- Response #6 AMP would need to integrate using digital inputs.
- Question #7 7.1.1 Video Resolution: HD 1080p Cameras with onboard analytics  
Can you please provide further clarification on “onboard analytics”? Will analytics on the local recorder suffice?
- Response #7 The cameras must be able to be configured for different frame rates, image quality, and motion detection. AMP wants the cameras to only record when they detect movement. The cameras need to be able to distinguish between birds and humans and shadows. These configurations and analytics can be performed within the camera or local recorder.
- Question #8 3.1.2.14.2. Configure and secure to meet NERC CIP security standards.  
Can you please specify the standard, i.e. 005 and 007?
- Response #8 The equipment needs to meet those two standards.
- Question #9 8.6.5 Specify communication medium i.e. WIFI, 4G, Line of Sight  
If cellular is proposed as the communication medium, does AMP have a preferred wireless vendor (Verizon, AT&T, etc.)?
- Response #9 AMP currently uses Verizon; hence, AMP prefers Verizon. If another wireless vendor is required or recommended, AMP is willing to use another wireless vendor. Please provide explanations for using a specific wireless vendor other than Verizon.
- Question #10 Attachment D – Proposal Form A-F : 10 space, 17-1/2” x 15”, well rack with locking front door  
Can you please provide an example of what a “10 Space” is?
- Response #10 The rack would need to be able handle the installation of 10 rack units (i.e., 1.752 inches per rack unit).

To assure that all Proposers have received this Addendum No. 1, proposers are required to acknowledge receipt of this information in the Cost Proposal Form (Attachment D).

Roger Yang  
Utility Procurement Administrator